

PRI Construction Materials Technologies LLC

6412 Badger Drive Tampa, FL 33610 813.621.5777 https://www.pri-group.com/

Laboratory Test Report

Report for:	Aida Ricetti Hardscape.com 15132 Park of Commerce Bl Jupiter, FL 33487	lvd. Ste # 103					
Product Name(s):	Blue Mist						
Project No.:	2275T0006.7						
Dates Tested:	Aug. 13, 2024						
Test Methods:	ASTM C1371 ASTM C1549 ASTM E1980						
Results Summary:							
,	Product	SRI, Me	edium-Wind				
	Blue Mist		40				
Purpose:	Determine the solar reflectan of the tested product(s).	nce, thermal e	mittance, and	d solar reflectance index value(s)			
Test Methods:	The test methods used included ASTM C1549-16: Standard Test Method for Determination of Solar Reflectance Near Ambient Temperature Using a Portable Reflectometer, Procedure B and ASTM C1371-15: Standard Test Method for Determination of Emittance of Materials Near Room Temperature Using Portable Emissometers. Thermal emittance measurement for samples was modified in accordance with Devices and Services Company's Tech Note 04-1. Both of these methods are Energy Star, Leadership in Energy and Environmental Design (LEED), and Cool Roof Rating Council (CRRC) approved methods for determining radiative properties.						
	The solar reflectance index (SRI) was calculated in compliance with ASTM E1980-11: Standard Practice for Calculating Solar Reflectance Index of Horizontal and Low-Sloped Opaque Surfaces.						
Sampling:	The following materials were received by PRI.						
	Product	Source	<u>Date</u>	Sampling			
	Blue Mist	Jupiter, FL	Aug. 9, 2024	Hardscape.com			

2275T0006.7

The test results, opinions, or interpretations are based on the material supplied by the client. This report is for the exclusive use of stated client. No reproduction or facsimile in any form can be made without the client's permission. This report shall not be reproduced except in full without the written approval of this laboratory. PRI Construction Materials Technologies LLC assumes no responsibility nor makes a performance or warranty statement for this material or products and processes containing this material in connection with this report.

PRI Construction Materials Technologies LLC 6412 Badger Drive Tampa, FL 33610 Tel: 813-621-5777 Fax: 813-621-5840 e-mail: materialstesting@pri-group.com WebSite: http://www.pri-group.com

Results: All measurements were recorded at 73.4±1.8°F & 50±5%RH

ASTM E 1980

	Solar Reflectance		Thermal Emittance		SRI		
Product	ASTM C1549 ¹		ASTM C1371 ²		ASTM E1980 ³		
	Avg.	Std.Dev.	Avg.	Std.Dev.	Low-Wind	Med-Wind	High-Wind
Blue Mist - 24" x 24" x 1-1/8"	0.365	0.004	0.88	0.01	39	40	41

Note(s): 1- Reflectance measurements were conducted using a Devices and Services SSR-ER Version 6.4 Reflectometer operated in v5 emulation mode and calibrated with Devices and Services Reference Tile # D-18.

2- Emittance measurements were conducted using a Devices and Services Emissometer Model AE calibrated with Devices and Services Reference Standards: High Emittance: 0.86 and Low Emittance: 0.06. Thermal emittance measurement for sample was modified in accordance with Devices and Services Company's Tech Note 04-1.

3- SRI calculations per ASTM E 1980 Approach II utilize the following assumptions: Low-Wind $h_c = 5 \text{ W/m}^2 \text{ K}$, Medium-Wind $h_c = 12 \text{ W/m}^2 \text{ K}$, and High-Wind $h_c = 30 \text{ W/m}^2 \text{ K}$.

Statement of Attestation: The Solar Reflectance Index of these samples was calculated in accordance with ASTM E 1980: Standard Practice for Calculating Solar Reflectance Index of Horizontal and Low-Sloped Opaque Surfaces. The laboratory test results presented in this report are representative of the materials supplied.

Signed	d:	Authrey	Cat	lett	
		Anthon	y Catlett		
Manager					
Date:		Aug. 1	3, 2024		
Report	Issue Hist	ory:			
	Issue #	Date	Pages	Revision Description (if applicable)	
(Original	08/13/2024	2	NA	

END OF REPORT

2275T0006.7

The test results, opinions, or interpretations are based on the material supplied by the client. This report is for the exclusive use of stated client. No reproduction or facsimile in any form can be made without the client's permission. This report shall not be reproduced except in full without the written approval of this laboratory. PRI Construction Materials Technologies LLC assumes no responsibility nor makes a performance or warranty statement for this material or products and processes containing this material in connection with this report.

PRI Construction Materials Technologies LLC 6412 Badger Drive Tampa, FL 33610 Tel: 813-621-5777 Fax: 813-621-5840 e-mail: materialstesting@pri-group.com WebSite: http://www.pri-group.com