

PRI Construction Materials Technologies LLC

6412 Badger Drive Tampa, FL 33610 813.621.5777 https://www.pri-group.com/

Laboratory Test Report

Report for:	Aida Ricetti Hardscape.com 15132 Park of Commerce Blvd. Ste # 103 Jupiter, FL 33487						
Product Name(s):	Coralina Ivory						
Project No.:	2275T0006.2						
Dates Tested:	Aug. 13, 2024						
Test Methods:	ASTM C1371 ASTM C1549 ASTM E1980						
Results Summary:							
······	Product	SRI, Me	dium-Wind				
	Coralina Ivory		59				
Purpose:	Determine the solar reflectane of the tested product(s).	ce, thermal er	nittance, and	l solar reflectance index value(s)			
Test Methods:	The test methods used included ASTM C1549-16: Standard Test Method for Determination of Solar Reflectance Near Ambient Temperature Using a Portable Reflectometer, Procedure B and ASTM C1371-15: Standard Test Method for Determination of Emittance of Materials Near Room Temperature Using Portable Emissometers. Thermal emittance measurement for samples was modified in accordance with Devices and Services Company's Tech Note 04-1. Both of these methods are Energy Star, Leadership in Energy and Environmental Design (LEED), and Cool Roof Rating Council (CRRC) approved methods for determining radiative properties.						
	-	-		mpliance with ASTM E1980-11: ex of Horizontal and Low-Sloped			
Sampling:	The following materials were received by PRI.						
	Product	Source	<u>Date</u>	Sampling			
	Coralina Ivory	Jupiter, FL	Aug. 9, 2024	Hardscape.com			

2275T0006.2

The test results, opinions, or interpretations are based on the material supplied by the client. This report is for the exclusive use of stated client. No reproduction or facsimile in any form can be made without the client's permission. This report shall not be reproduced except in full without the written approval of this laboratory. PRI Construction Materials Technologies LLC assumes no responsibility nor makes a performance or warranty statement for this material or products and processes containing this material in connection with this report.

PRI Construction Materials Technologies LLC 6412 Badger Drive Tampa, FL 33610 Tel: 813-621-5777 Fax: 813-621-5840 e-mail: materialstesting@pri-group.com WebSite: http://www.pri-group.com

Results: All measurements were recorded at 73.4±1.8°F & 50±5%RH

ASTM E 1980

	Solar Reflectance		Thermal Emittance		SRI		
Product	ASTM C1549 ¹		ASTM C1371 ²		ASTM E1980 ³		
	Avg.	Std.Dev.	Avg.	Std.Dev.	Low-Wind	Med-Wind	High-Wind
Coralina Ivory - 16" x 32" x 3/4"	0.515	0.006	0.87	0.00	59	59	60

Note(s): 1- Reflectance measurements were conducted using a Devices and Services SSR-ER Version 6.4 Reflectometer operated in v5 emulation mode and calibrated with Devices and Services Reference Tile # D-18.

2- Emittance measurements were conducted using a Devices and Services Emissometer Model AE calibrated with Devices and Services Reference Standards: High Emittance: 0.86 and Low Emittance: 0.06. Thermal emittance measurement for sample was modified in accordance with Devices and Services Company's Tech Note 04-1.

3- SRI calculations per ASTM E 1980 Approach II utilize the following assumptions: Low-Wind $h_c = 5 \text{ W/m}^2 \text{ K}$, Medium-Wind $h_c = 12 \text{ W/m}^2 \text{ K}$, and High-Wind $h_c = 30 \text{ W/m}^2 \text{ K}$.

Statement of Attestation:The Solar Reflectance Index of these samples was calculated in accordance with ASTME 1980:Standard Practice for Calculating Solar Reflectance Index of Horizontal and
Low-Sloped Opaque Surfaces.The laboratory test results presented in this report are
representative of the materials supplied.

Sign	ed:	Muthrey	Cat	Hett
		Anthon	y Catlett	
		Mar	lager	
Date	::	Aug. 1	3, 2024	
Repor	t Issue Histo	ory:		
	Issue #	Date	Pages	Revision Description (if applicable)
	Original	08/13/2024	2	NA

END OF REPORT

2275T0006.2

The test results, opinions, or interpretations are based on the material supplied by the client. This report is for the exclusive use of stated client. No reproduction or facsimile in any form can be made without the client's permission. This report shall not be reproduced except in full without the written approval of this laboratory. PRI Construction Materials Technologies LLC assumes no responsibility nor makes a performance or warranty statement for this material or products and processes containing this material in connection with this report.

PRI Construction Materials Technologies LLC 6412 Badger Drive Tampa, FL 33610 Tel: 813-621-5777 Fax: 813-621-5840 e-mail: materialstesting@pri-group.com WebSite: http://www.pri-group.com